



OBJT2.E206440

(Plastic Materials and Electrical Insulation Systems) Special Transformer Wind Wire - Component

[Page Bottom](#)[Questions?](#)[Previous Page](#)

(Plastic Materials and Electrical Insulation Systems) Special Transformer Wind Wire - Component

[Guide Information](#)

FURUKAWA ELECTRIC CO LTD
HIRATSUKA MAGNET WIRE WORKS
5-1-9 HIGASHI YAHATA
HIRATSUKA-SHI
KANAGAWA 254-0016, JAPAN

E20

Cat Nos. FSX-E, SX-E, basic insulation rated 105° C, working voltage 354 Vdc or Vp.

Cat No. FWX-E, supplementary insulation rated 120° C, working voltage 354 V dc or Vp.

Cat Nos. TEX-E, TEX-EA, reinforced insulation rated 105° C, working voltage of up to 1.4 kV.

Cat No. TEX-ELZ, reinforced insulation rated 105° C, working voltage of up to 1.4 kV.

Cat No. TEX-ECEW3, reinforced insulation rated 105° C, working voltage of up to 1.4 kV.

Cat No. TEX-F, reinforced insulation rated 105° C, working voltage of up to 1.4 kV.

Cat No. TEX-B, reinforced insulation rated 130° C, working voltage of up to 1.4 kV.

Marking: Company name and material designation on package, reel or on tag attached to the end of the wire and Recognized Component Mark.

[Page Top](#)[Notice of Disclaimer](#)[Questions?](#)[Previous Page](#)[UL Listed and Classified Products](#)[UL Recognized Components](#)[Products Certified for Canada](#)

This page and all contents are Copyright ©2002 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on product.